



## Fort Davis RC Lead in Water Test Results

### FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005385	7/13/2020	7/13/2021	1	Cooler	In hallway adjacent to room 103	WF-07132020-005385	4/12/2021	FT-FY21-042021-005385-A	<1	FT-FY21-042021-005385-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005386	2/9/2021	2/9/2022	1	Food Prep Sink	In pantry room 104 in kitchen	WF-02092021-005386	4/12/2021	FT-FY21-042021-005386-A	<1	FT-FY21-042021-005386-B	<1